



B/W TYPE L.H. RELAY - AW21

Submersible Pump Monitoring Controls

FEATURES

Complete installation requires two electrodes and suspension wire in addition to relay.

Electrodes AW22 - Type E-1S Brass, with plastic insulating shield $\frac{5}{8}$ diameter (2 required).

Suspension Wire - No.18 stranded wire with $\frac{1}{16}$ " vinyl insulation. Sold only in 500' or 1000' rolls.

ORDER NUMBERS

Relay Order No.	Volts	Rating
AW21-1	115V 1Ø	up to 1 HP*
AW21-2	230V 1Ø 230V 3Ø	
AW21-3	460V 3Ø	

* When used with motors which exceed their ratings, controls must be wired to pilot circuit of a magnetic starter or contactor.

Order No.	Description
AW23R5	500' #18 Red Wire
AW23B5	500' #18 Black Wire
AW23R10	1000' #18 Red Wire
AW23B10	1000' #18 Black Wire
AW22	(2) Type E-1S Electrodes



Xylem, Inc.
2881 East Bayard Street Ext., Suite A
Seneca Falls, NY 13148
Phone: (866) 325-4210
Fax: (888) 322-5877
www.xylem.com/goulds

Xylem is a registered trademark of Xylem Inc. or one of its subsidiaries. Goulds is a registered trademark of ITT Manufacturing Enterprises LLC and is used under license. All other trademarks or registered trademarks are property of their respective owners.
© 2023 Xylem Inc. BAW21 R2 March 2023